



Government of Karnataka

Sl.No: Aee/PWD/Anekal/2024-25/425/25.09.2024

Office of the Assistant Executive engineer
PWD Sub-Division, Anekal

Annexure-D

BUILDING SAFETY CERTIFICATE

It is certified that the existing building **Aspire Bee School (MS MILLENNIUM EDUCATION TRUST)** (name of the building or premises) at Survey no. 36/3, 37/5, 39/7, Sulikunte-Chokkasandra road, Varthur Hobli, Bengaluru East Taluk, Bengaluru-562125 (address) is having block(s)/Floor(s) as per details below:

Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	Ground Floor-01 First Floor-01 Second Floor-01 Third Floor-01 Total =04(G+3)	NA	NA	NA	NA	NA

The building is owned/occupied by **Aspire Bee School (MS MILLENNIUM EDUCATION TRUST)** (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of **The Assistant Executive Engineer, PWD Sub Division, Anekal Taluk, Bangalore Urban District** (Name of Department/ Govt.) on **21.09.2024** (date of inspection) in the presence of **Secretary, Aspire Bee School (MS MILLENNIUM EDUCATION TRUST)** and **Assistant Executive Engineer, PWD Sub Division, Anekal Taluk** (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school and up to Class (X) with effect from **25.09.2024** to **24.09.2026** for a period of **2** years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Flagging Concrete Should be layed allround the building.
2. Parapet Observed during inspection is 1.20m and the same should be raised to suitable safe height.
3. WPC in 3rd Floor Should be applied properly.

Issued on **11.06.2025** at **Anekal** by The Assistant Executive Engineer- PWD Sub Division

* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

Signature with Seal

[Signature]
Assistant Executive Engineer
P.W.D. Sub-Division
ANEKAL 562-106

Designation : Assistant Executive engineer
PWD Sub-Division
Anekal